



**ENERGY SAVING REPORT – CARRIER SPLIT
AC UNIT AT SCHLUMBERGER,
NIZWA**

(Prepared on 07th November 2020)

PROJECT & CLIENT DETAILS

- ❖ Client Details : SCHLUMBERGER, NIZWA BASE, OMAN
- ❖ Project Reference : SCHLUMBERGER, NIZWA BASE, OMAN
- ❖ Equipment Details : 3.0 TR, Carrier Make Split AC Unit

Table -1

Sr. No	TR	Model	Serial No	Location
1	3.0	Carrier Split AC Unit 38FN0362120B	NA	Conference/ Meeting Room

PROJECT LOCATION



SCHLUMBERGER, NIZWA BASE

Executive Summary

MAXR100 PERFORMANCE TEST

A test of the impact of MAXR100 treatment on Split AC unit had been conducted by M/s. Ganatra International LLC, Muscat at Schlumberger Nizwa base, Oman.

- ❖ Number of unit's data logged – 01 (*Ref: Table-1*)
- ❖ Set conditions in the facility:
 - Set point for the Split AC unit has been maintained at 21°C
 - The set point is maintained constant throughout the pre-data logging and the

last post data logging. (Ref for dates - Table-2)

- Temperature Hygrometer has been placed close to the outdoor unit to correlate the effect of ambient temperature on Energy consumption.
- ❖ The Measurement & Verification for the savings project is as per the test protocol agreed between Ganatra International LLC & Schlumberger.
 - The data logging has been carried out for more than 100 hours during the pre-installation benchmarking and the post-installation reporting.
 - The power parameters of the split unit have been recorded for every 15 mins.
 - The data attained during pre-measurement is solely based on instantaneous values and Energy (KWh).
 - The data obtained during the post-measurement are RMS values which differ with the pre-measurement due to change in data logger (advanced).
 - The benchmark detailed in this report has been revised to standardize the pre-measurement and post-measurement data.
- ❖ This document contains the Savings report of the Split AC Unit of Capacity 3.0TR
- ❖ **Pre & Post Data Logging period:**

Sr. No	TR	Model	Pre-Data period	Post Data Period
1	3.0	Carrier Split AC Unit 38FN0362120B	22/10/2019 to 18/11/2019	11/10/2020 to 18/10/2020

Table - 2

Summary Conclusion:

Unit Capacity	Unit Type	Savings in %
3.0 TR	Split AC Unit	22%

A). Energy Saving Report of Carrier Make 3.0 TR Split AC unit Model 38FN0362120B, Serial. No. NA, at Schlumberger for Trial with MAXR100

(Total 03 Pages)

I	Client Details	SCHLUMBERGER – NIZWA BASE, OMAN
a	Project Name & Address	SCHLUMBERGER – NIZWA BASE, OMAN
II	Equipment Details	
a	Capacity& Location	3.0 TR, Conference/Meeting Room
b	Make &Model	Carrier – 38FN0362120B
c	Serial Number	NA
d	Refrigerant	R- 22
III	MaxR100 - Test Period	
a	PRE-Measurement Period	22 nd October 2019 to 18 th November 2019
b	POST-Measurement Period	11 th November 2020 to 18 st November 2020

B). Summary of PRE & POST Data - Carrier Make 3.0 TR Split AC unit Model 38FN0362120B, Serial. No. NA, at Schlumberger for Trial with MAXR100

COMPARATIVE STUDY	PRE-DATA	POST DATA
Total Operated Hours	141.75	135.75
Total Energy Consumed in Kwh	387.3	289.0
Average energy consumption/Hour in Kwh	2.73	2.13
Average Load Demand in KW	2.82	2.14
Average Line to Neutral Voltage in VLN	234.1	240.2
Average Current in Amps	12.3	9.3
Average Power Factor in PF	0.906	0.961
Average Ambient Temperature	32.6	32.9
Average Relative Humidity in %	17.8	17.1

Note: Kindly refer to the excel sheets provided for the data and summary



Microsoft Excel
97-2003 Worksheet

C). Conclusion - Energy Savings with MaxR100:

- | | | |
|---|---|--|
| ➤ Average Energy Consumption/ Hour - PRE | : | 2.73 KWH |
| ➤ Average Energy Consumption/ Hour - POST | : | 2.13 KWH |
| ➤ Difference | : | 2.73 - 2.13 = 0.6 KWH/ Hour |
| ➤ Improvement with MAXR100 in % | : | $(0.6/2.73) \times 100 = 22\%$ |

Observations:

- The operating time of the unit during the post data logging has drastically reduced due to frequent cut-offs. Such kind of operation from a split unit can be observed when the unit reaches the set point quicker.
- Due to frequent cut-offs from the split unit, the data is considered for six whole days and therefore the pre-data has been revised for six whole days to make an apple to apple comparison on performance.
- The pre-data logging and the post-data logging have been conducted in the same month (October) in two different years (2019, 2020) with same settings (21°C) and similar ambient temperatures (32.6°C & 32.9°C), the result in observed in total energy consumed in six days broken down to KWh/hr.